

COMPLIANCE SCHEDULE DETAILS: SS 12/2 - FM RADIO FREQUENCY SYSTEMS AND INFRARED BEAM TRANSMISSION SYSTEMS



PLEASE PROVIDE THE FOLLOWING INFORMATION

Date:

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.

Applicant name:	Building name:
Site address:	Classified Use:
Existing Compliance Schedule Number(s): (if applicable)	Risk/purpose group:
	Fire hazard category:
	Total occupant load:

SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY)

Specified systems:	Existing	New	Modified	Removed
Type:	FM radio frequency system			
	Infrared (IR) beam transmission system			
Location plan for specified systems and records is attached: Yes No				
No.	Equipment location	Make (main components)	Model	
1				
2				
3				
4				
5				

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Performance/ installation:	<p>BS EN IEC 60118-4:2015+A1:2018 Electroacoustics. Hearing aids. Induction-loop systems for hearing aid purposes. System performance requirements</p> <p>IEC 60118.4:2014+Amd 1:2017 Electroacoustics. Hearing aids - part 4 - induction-loop systems for hearing aid purposes. System performance requirements</p> <p>AS 60118.4-2007 Hearing aids magnetic field strength in audio-frequency induction loops for hearing aid purposes</p> <p>AS 1088.4:1987: Hearing aids. Magnetic field strength in audio-frequency induction loops for hearing aid purposes</p> <p>Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)</p> <p>Other:</p>
-------------------------------	--

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Inspections:	AS 60118.4-2007 Other:	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).
Maintenance:	AS 60118.4-2007 Other:	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

Minimum inspection and maintenance procedures:	Regular inspections and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard/document to ensure continued effective operation of the system during occupation of the building.
--	--

Inspection frequency and responsibility:	Depending on the type of installation and its performance standard/document: Specifically designed solutions: by IQP only Standard /other document: Six-monthly: Owner IQP
--	--

Inspections & Maintenance: Six Monthly Inspections	<p>As a minimum, these inspections will include the inspection and testing of:</p> <ul style="list-style-type: none"> • Signal transmission strength. • FM transmission and availability of good reception in the indicated public area – any coverage blank spots will be eliminated or marked. (NOTE: Where IR transmission is used, blank spots may be caused by pillars, obstructions or poor placement of emitters, as reception is dependent on direct line transmission). • Receiver settings - will be set for the transmission channel used at the venue. <p>General:</p> <p>Where only FM transmission is available, and users provide their own receivers: the system will be tested for proper operation and full area coverage.</p> <p>Where receiver units and relevant listening devices are available for public hire: they will be inspected to ensure:</p> <ul style="list-style-type: none"> o The specified number of receivers are available for use. o The following items should also be tested to ensure they are functioning properly, being used correctly and in good condition: <ul style="list-style-type: none"> • Cords • Connectors • Tele loop (where used) • Stethoclip, earplugs • Headset <p>Where equipment is available for hire: earplugs, headset covers, or ear pads will be sanitised and sealed in a bag or replaced after each use.</p> <p>Rechargeable batteries used in the receivers will be recharged after each use to ensure full operating capacity. Responsive maintenance will be applied to ensure continued operation during occupation of the building. In particular the following will be carried out.</p> <p>Where a component of the assistive listening system is found to be faulty or not operating as required it will be repaired or replaced without undue delay.</p>
---	--

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

Reporting:

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work.
- Form 12A provided annually by the IQP.