

COMPLIANCE SCHEDULE DETAILS: SS 2 - AUTOMATIC/MANUAL EMERGENCY WARNING SYSTEMS (ALARMS)



PLEASE PROVIDE THE FOLLOWING INFORMATION

Date:

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.

Applicant name:	Building name:
Site address:	Classified Use
Existing Compliance Schedule Number(s): (if applicable)	Risk/purpose group:
	Fire hazard category:
	Total occupant load:

SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY)

Specified systems:	Existing	New	Modified	Removed
Type:	Monitored non-standard School Security Warning System (SSWS)			
	Monitored non-standard Security Based Warning System (SBWS)			
	Type 2: Manual warning systems Type 3: Automatic fire alarm system with heat detectors and manual call points Type 4: Automatic fire alarm system with smoke detectors and manual call points Type 5: Automatic fire alarm system with modified smoke / heat detection and manual call points A carbon monoxide gas detection system within a car park building that warns occupants of a potentially hazardous concentration of gas Other: (specify)			

Response: (i.e. warning)	Manual	Automatic	
Supplementary devices: (i.e. detection)	Heat detectors	Smoke detectors	Gas detectors
Alarm interfacing: [specify e.g. SS1, SS3/3, SS9]			

Location plan for specified systems and records is attached: Yes No

No.	Equipment location	Make (main components)	Model
1			
2			
3			
4			
5			
6			

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Performance/
installation:

NZS 4512:2010 Fire detection and alarm systems in buildings
NZS 4512:2003 Fire detection and alarm systems in buildings
NZS 4512:1997 Fire alarm systems in buildings
NZS 4512:1994 Fire alarm systems in buildings
NZS 4512:1981 Automatic fire alarm systems in buildings
NZS 4514:2009 Interconnected smoke alarms for houses
NZS 4514:2002 Interconnected smoke alarms for single household units
NZS 4514:1989 The installation of smoke alarms
NZS 4561:1973 Specification for manual fire alarm systems for use in buildings
AS 1851:2005 Maintenance of Fire Protection Systems and Equipment

Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other _____

Inspections:

NZS 4512:2010 Part 6
NZS 4512:2003 Part 6
NZS 4512:1997 Part 6
NZS 4512:1981 Part 4
AS 1851:2005 Section 6.4, 7.4, 8.4

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Maintenance:

NZS 4512:2010 Part 6
NZS 4512:2003 Part 6
NZS 4512:1997 Part 6
NZS 4512:1981 Part 4
NZS 4514:2009 Part 6
NZS 4561:1973 Appendix A
AS 1851:2005 Section 6.4, 7.4, 8.4

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

Minimum inspection and maintenance procedures:	Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection Standard/document, to ensure the system will operate as required in the event of a fire or other danger.			
Inspection frequency and responsibility:	Specifically designed solutions	By IQP		
	School Security Warning System (SSWS):	<ul style="list-style-type: none"> • Monthly: by school representative • Six Monthly: by security alarm maintenance contractor • Annual: <table style="margin-left: 20px; border: none;"> <tr> <td style="padding-right: 20px;">IQP</td> <td>Security alarm maintenance contractor</td> </tr> </table> 	IQP	Security alarm maintenance contractor
	IQP	Security alarm maintenance contractor		
	Security Based Warning System (SBWS)	<ul style="list-style-type: none"> • Weekly: (sounders) by Owner / Representative • Quarterly: (sounders & smoke detectors) by IQP only • Annually:(sounders & smoke detectors plus annual survey) by IQP only 		
	Manual warning systems (Type 2f alarm)	<ul style="list-style-type: none"> • Monthly: (Sounders) by IQP only • Quarterly: (Sounders) by IQP only • Annually: by IQP only 		
Automatic fire alarm system (Type 3, 4, 5, 6, 7)	<ul style="list-style-type: none"> • Monthly: (Sounders) by IQP only • Quarterly: (Sounders) by IQP only • Annually: by IQP only 			
Reporting:	<p>The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include:</p> <ul style="list-style-type: none"> • Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work • Form 12A provided annually by the IQP. 			